



**Mrs. Claudine Verbeke**  
**Lampe\_Textiles**  
**Kanegemstraat 29**  
**B-8700 Tielt**

**Your message - reference**

-

**our reference**

PW/0118

**Gent**

2019-01-31

Certification report 19/0118

---

## 1. Description of the product:

<b>Product family</b>	Polyester self-adhesive textile for window covering
<b>Total mass</b>	Ca. 110 g/m <sup>2</sup>
<b>Thickness</b>	Ca. 0.3 mm

## 2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT •** Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)

**VAT •** BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

**addressee**

Lampe\_textiles

**our reference**

PW/0118

**Gent**

2019-01-31

**page**

2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

**B - s1, d0**

*Attached to a Calcium Silicate plate (870 kg/m<sup>3</sup> or more) with a minimum thickness of 11 mm*

**Related commercial names to this product group**

Squid® Chalk-Bone-Oak-Ash-Rock-Coal

**The obtained classification is based on the next test reports**

CREPIM: 1039/72/284 A

**Validity of the certificate**

20-10-2021

Petra Wittevrongel

Product Certifier

